

Appendix H

Helpful Formulas

Computing Flow from BTU/h	
Simplified formula	$GPM = BTU/h \div (\Delta t \times 500)$
Example: Determine the flow of 286,000 BTU/h at a 20°F differential temperature.	$GPM = 286,000 \div (20 \times 500)$ $GPM = 286,000 \div 10,000$ $GPM = 28.6$

Calculating Active Loop Length	
Note: The leader length must be added to the active loop length in order to obtain the total loop length.	Room ft ² x 1.0 = active loop at 12" o.c. Room ft ² x 1.2 = active loop at 10" o.c. Room ft ² x 1.33 = active loop at 9" o.c. Room ft ² x 1.5 = active loop at 8" o.c. Room ft ² x 1.7 = active loop at 7" o.c. Room ft ² x 2.0 = active loop at 6" o.c.

Amount of Joist Trak™ Panels (A5080375, A5080500)	
Active loop length x 0.2125	
Amount of Quik Trak® Panels (A5060701) and Returns (A5060702)	
Room ft ² x 0.386 (panels)	
Room ft ² x 0.043 (returns)	

Amount of PEX Clips (F7060375, F7051258, F7057500, F7051001)	
Active Loop Length ÷ 3	

Floor Surface Temperature	
$(BTU/h/ft^2 \div 2.0) + \text{Room setpoint}$	

Supply Fluid Temp. After First Injection Point on Primary Loop	
$(F_A \times T_A) + (F_B \times T_B) = (F_C \times T_C)$	
F_A = Primary flow rate after injection leg F_B = Flow rate for return injection leg F_C = Primary flow rate after return leg T_A = Primary temp. after injection leg T_B = Return temp. on return injection leg T_C = Primary temp. after return leg	

Example: Given the detail above, calculate the primary loop (boiler loop) temperature after the first injection location.	$(7 \times 180) + (3 \times 160) = 10x$ $1260 + 480 = 10x$ $1740 = 10x$ $174 = x$ The primary loop temperature after the first injection location is 174°F.
--	---

Injection Pump Flow Rates	
Refer to Appendix I for more information	
$F_V = (F_1 \times T_D) \div (T_1 - T_R)$	
F_V = Flow rate (injection loop) in gpm F_1 = Radiant (secondary loop) flow rate in gpm T_1 = Boiler (primary loop) supply temp. T_2 = Radiant (secondary loop) supply temp. T_R = Radiant (secondary loop) return temp. T_D = Radiant (secondary loop) differential temp.	
Example: If values at design condition are:	Find the injection pump flow rate.
$F_1 = 30$ gpm	$F_V = (30 \times 10) \div (180 - 120)$
$T_1 = 180^\circ F$	$F_V = (300) \div (60)$
$T_2 = 130^\circ F$	$F_V = 5$ gpm
$T_R = 120^\circ F$	
$T_D = 10^\circ F$	

Loading for Motorized Valve Actuators (MVA)	
Computed at a minimum 10% line loss	
MVA draw: 0.29 amps	
Amps x volts = current	
$0.29 \times 24 = 6.96$ VA per MVA	
Example:	
$50 \text{ VA} \div 6.96 \text{ VA} = 7.18 \times 0.9 = 6.5$ (10%)	
6 MVA per 50 VA transformer	
40VAC transformer = 5 MVA	
50VAC transformer = 6 MVA	
75VAC transformer = 9 MVA	
100VAC transformer = 12 MVA	

Loading for Thermal Actuators (TA)	
Computed at a minimum 10% line loss	
TA initial draw: 0.1458 amps	
Amps x volts = current	
$0.1458 \times 24 = 3.5$ VA per TA	
Example:	
$50 \text{ VA} \div 3.5 \text{ VA} = 14.29$	
$14.29 \times 0.9 = 12.83$ (10% reduction)	
12 TAs per 50 VA transformer	
40VAC transformer = 10 TA	
50VAC transformer = 12 TA	
75VAC transformer = 19 TA	
100VAC transformer = 25 TA	

Continued on next page

Appendix H

Helpful Formulas

Continued...

Loading for Thermal Actuators (TA) Computed at a minimum 10% line loss

Fuel consumption based on degree day:

$$F = \frac{HL \times 24 \times DD}{E \times P \times TD}$$

HL = Heating load (BTU/h)

24 = Hours in a day

DD = Degree day

E = Boiler efficiency (AFUE)

P = Heating value of fuel (BTU)

TD = Temperature differential

F = Annual fuel consumption

Example: A 40,000-square-foot hangar in Bangor, Maine using an 82% AFUE oil boiler (Number 2 fuel oil). The heat load for the hangar is 1,288,128 BTU/h at design. Outside design temperature is -11°F with an indoor setpoint temperature of 65°F. Number 2 fuel oil is priced at \$0.80 per gallon.

$$F = \frac{1,288,128 \times 24 \times 8,220}{0.82 \times 138,000 \times 76}$$

$$F = \frac{254,121,891.840}{8,662,480}$$

F = 29,335.93 gallons of fuel oil

F = 29,335.93 x 0.80 = \$23,469/season

Fuel Comparison in BTU

Natural Gas	100,000 BTU per 1 CCF (1 therm.)
Propane	91,800 BTU per gallon
No. 2 Fuel Oil	139,000 BTU per gallon
Kerosene	134,000 BTU per gallon
Electric	3,412 BTU per Kilowatt Hour (KWH)
Wood	14,000,000 BTU per cord (mixed)

Supply and Return Pipe Sizing (at a 10°F Δt)

Tubing	BTU/h	GPM	Pipe Size (in.)
Copper	10K – 20K	2 – 4	¾"
	20K – 45K	4 – 9	1"
	30K – 80K	6 – 16	1¼"
	50K – 105K	10 – 21	1½"
	100K – 225K	20 – 45	2"
Multi-layer Composite (MLC)	10K – 20K	2 – 4	¾"
	20K – 45K	4 – 8	1"
PEX (Wirsbo hePEX™ and Uponor AquaPEX®)	2.5K – 10K	0.5 – 2	½"
	5K – 15K	1 – 3	¾"
	15K – 25K	3 – 5	1"
	20K – 45K	4 – 9	1¼"
	30K – 70K	6 – 14	1½"
High-density Polyethylene (HDPE)	75K – 205K	15 – 41	2"
	150K – 575K	30 – 115	3"
	250K – 1,125K	50 – 225	4"

Boiler Main Pipe Sizing (at a 20°F Δt)

Tubing	BTU/h	GPM	Pipe Size (in.)
Copper	20K – 40K	2 – 4	¾"
	40K – 90K	4 – 9	1"
	60K – 160K	6 – 16	1¼"
	100K – 210K	10 – 21	1½"
	200K – 450K	20 – 45	2"